



Certificate of Compliance

Certificate: 1148050 (LR 78034-1))

Master Contract: 155531

Project: 2084254

Date Issued: 2008/09/05

Issued to: Automatic Valve Corporation

41144 Vincenti Ct

Novi, MI 48375-1922

USA

Attention: Mr. T. Hutchins

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by:

A. Jeung P. Eng.
Anthony Yeung P. Eng.

Authorized by:

Rick Morrison, P. Eng.,
Product Group Manager

PRODUCTS

CLASS 3221 81 - VALVES - Certified to US Standards

CLASS 3221 01 - VALVES

General purpose valves (for air only) Series "A" through "Z" or "1" through "5", totally enclosed, water proof type Enclosures 3, 3S, 4, 4X, with suffixes:

B-XX; C-XX; D-XX; E-XX; F-XX; P-XX; S-XX; V-XX; W-XX; X-XX; Y-XX; or Z-XX. XX represents the

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1148050 (LR 78034-1))

Master Contract: 155531

Project: 2084254

Date Issued: 2008/09/05

voltage code max rating of 240V ac, max wattage of 12, min insulation of Class B, and max pressure of 150 psi.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No. 139-1982 - Electrically Operated Valves

UL Std No. 429 - Electrically Operated Valves



Supplement to Certificate of Compliance

Certificate: 1148050

Master Contract: 155531

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2084254	2008/09/05	updating of report 1148050 to replace the illustration attachments